



NOTE: ALL ITEMS SHALL COMPLY WITH THE FOLLOWING

- REDUCED PRESSURE BACKFLOW ASSEMBLY SHALL BE A MAKE AND MODEL APPROVED BY THE WASHINGTON STATE DEPARTMENT OF HEALTH.
- REDUCED PRESSURE BACKFLOW ASSEMBLY IS TO LAY HORIZONTAL ONLY.
- THE WATER LINE SHALL BE THOROUGHLY FLUSHED PRIOR TO INSTALLING THE BACKFLOW ASSEMBLY.
- THE BACKFLOW ASSEMBLY SHALL BE PROTECTED FROM FREEZING AND FLOODING.
- THE BACKFLOW ASSEMBLY SHALL BE INSTALLED A MINIMUM OF 12" ABOVE FINISHED GRADE.
- A PLUMBING PERMIT IS REQUIRED. IF SERVICE ADDRESS IS OUTSIDE CITY OF TUMWATER LIMITS CONTACT THURSTON COUNTY.
- THE BACKFLOW ASSEMBLY SHALL BE TESTED AFTER INSTALLATION, PRIOR TO ACCEPTANCE AND ALSO YEARLY THEREAFTER BY A CERTIFIED BACKFLOW ASSEMBLY TESTER.
- TEST RESULTS SHALL BE SENT TO THE CITY OF TUMWATER CROSS CONNECTION SPECIALIST.

